

JRC SCIENCE FOR POLICY REPORT

Heating and cooling demand forecast in Cyprus

Administrative Arrangement N° SI2.241078 Between DG EMPL and JRC **LIMITED DISTRIBUTION**

Ignacio Hidalgo Gonzalez

2015



This publication is a Science for Policy report by the Joint Research Centre, the European Commission's in-house science service. It aims to provide evidence-based scientific support to the European policy-making process. The scientific output expressed does not imply a policy position of the European Commission. Neither the European Commission nor any person acting on behalf of the Commission is responsible for the use which might be made of this publication.

JRC Science Hub

https://ec.europa.eu/jrc

JRC99717

© European Union, 2015

Reproduction is authorised provided the source is acknowledged.

How to cite: Hidalgo Gonzalez, I., Heating and Cooling Demand (Forecast) in Cyprus

All images © European Union 2015

Abstract

Heating and Cooling Demand (Forecast) in Cyprus

This report describes the rationale and the equations used to project the demand of energy services in Cyprus for the period 2013-2015, according to the methodology used by the JRC-EU-TIMES model. It describes the sets used in the model, the inputs and variables used in the equations, the general approach used in all sectors and the variants specific to the residential sector. Finally, the last section describes the projections resulting from these calculations.

Table of contents

Acknow	ledgen	nents	4
1.	Introd	duction	5
2.	Sets .		6
3.	Paran	neters	8
4.	Equ	uations	12
4.1	Sta	ndard demand equations	12
4	.1.1	Driver term	13
4	.1.2	Cost term	14
4	.1.3	Efficiency term	15
1.1	.1 E	lasticities	15
4.2	Ene	ergy demand in the residential sector	21
4	.2.1	Stock of dwellings by category	22
4	.2.2	Demand of energy services per dwelling	23
4	.2.3	Total demand of energy services	26
2			27
5 F	Results		28
5.1	Eco	pnomic and demographic assumptions	28
5.2	Ind	ustrial useful energy demand	29
5.3	Res	sidential energy demand	30
5.4	Cor	nmercial energy demand	34
5.4	Agr	iculture	37
6 R	eferend	ces	
List of f	figures.		39
List of t	tables		40

Acknowledgements

This report was made possible through contributions from the colleagues, who have been working on the implementation of this AA:

- Marta Santamaria
- Kostas Kavvadias
- Mindaugas Jakubcionis
- Carmen G Moles
- Ronald Piers de Raveschoot
- Johan Carlsson

Christodoulos Ellinopoulos of the Ministry of Energy, Commerce, Industry and Tourism of the Republic of Cyprus have provided data and useful feedback on assumptions made.

1. Introduction

This note describes the rationale and the equations used to project the demand of energy services in Cyprus for the period 2013-2015, according to the methodology used by the JRC-EU-TIMES model.

The document is structured as follows. Section 2 describes the sets used in the model. Section 3 describes the inputs and variables used in the equations. Section 4 describes the general approach used in all sectors (4.1) and the variants specific to the residential sector (4.2). Finally, section 5 describes the projections resulting from these calculations.

2. Sets

Set name (abbreviation)	Elements					
Countries TIMES (ct)	CY					
Countries TIMES EU28	CY					
Dwelling ages (da)	EXISTING, NEW					
Dwelling types (dt)	RURAL, URBAN, MULTIPLE					
Sector	Industry,Residential Cooling,Residential Heating,Residential Water,Residential Other,Commercial Cooling,Commercial Heating,Commercial Water,Commercial Other (for final reporting)					
Sector CY	NonNetallicMinerals,FoodDrinkTobacco,OtherIndustries,Cooling,Heating,Electric (email KK 18/09/2015)					
Sector PRIMES (sp)	Sector PRIMES Industry, Sector PRIMES Construction, Sector PRIMES Tertiary, Sector PRIMES Transport					
Sector PRIMES Construction (spc)	Construction					
Sector PRIMES Industry (spi)	Iron and steel, Non-ferrous metals, Chemicals, Non-metallic minerals, Paper pulp, Food drink and tobacco, Engineering, Textiles, Other industries					
Sector PRIMES Tertiary (sp3)	Market services, Non market services, Trade, Agriculture					
Sector PRIMES Transport (spt)	Public road transport, Private cars, Motorcycles, Rail, Aviation, Inland navigation, Trucks, Rail freight, Inland navigation freight					
Sector TIMES (st)	Sector TIMES Industry, Sector TIMES Residential, Sector TIMES Commercial, Sector TIMES Agriculture, Sector TIMES Transport					
Sector TIMES Agriculture (sta)	AGR					
Sector TIMES Commercial (stc)	CHSE, CHLE, CCSE, CCLE, CWSE, CWLE, CLIG, CCOK, CREF, CPLI, COEL, COEN, ONE					
Sector TIMES Industry (sti)	IIS, IAL, ICU, INF, ICH, IAM, ICL, ICM, ILM, IGH, IGF, INM, IPH, IPL, IOI, NEC, NEO					
Sector TIMES Residential (str)	RHRE, RHUE, RHME, RCRE, RCUE, RCME, RWRE, RWUE, RWME, RHRN, RHUN, RHMN, RCRN, RCUN, RCMN, RWRN, RWUN, RWMN, RLIG, RCOK, RREF, RCWA, RCDR, RDWA, ROEL, ROEN					
Sector TIMES Residential Cooling (strc)	RCRE, RCUE, RCME, RCRN, RCUN, RCMN					
Sector TIMES Residential Heat (strh)	RHRE, RHUE, RHME, RHRN, RHUN, RHMN					
Sector TIMES Residential Insulation (stri)	Sector TIMES Residential Insulation Existing, Sector TIMES Residential Insulation New					
Sector TIMES Residential Insulation Existing (strie)	RHRE, RHUE, RHME					

Set name (abbreviation)	Elements					
Sector TIMES Residential Insulation New (strin)	RHRN, RHUN, RHMN					
Sector TIMES Residential Water (strw)	RWRE, RWUE, RWME, RWRN, RWUN, RWMN					
Sector TIMES Transport (stt)	TCS, TCL, TBU, TBI, TFH, TFL, TMO, TTP, TTF, TTL, TAV, TAI, TNA, TNB					

3. Parameters

3.1 Constant values (input file "Constants AEEI eq 0 PE eq 0 DR new.csv")

Name	Unit	Description	Policy	Source
			parameter	
AEEI _{st}	Dmnl	Autonomous energy efficiency improvement rate	Yes	Existing data in JRC-EU-TIMES
CORRECTION	Dmnl	Calibration factor for alignment to 2013 energy balance	No	Calculated
DIFHEAT _{ct,dt}	Dmnl	Heat new dwellings compared to existing per category in the base year	No	Existing data in JRC-EU-TIMES
DWSTOCKBASE _{ct,dt}	d	Stock of dwellings in base year	No	Existing data in JRC-EU-TIMES
EFFEXI _{ct}	Dmnl	Annual heat efficiency improvement on existing dwellings because demolishing	Yes	Existing data in JRC-EU-TIMES
Mapping RD AGE	Dmnl	Mapping residential sectors-dwelling ages-dwelling types	No	Existing data in JRC-EU-TIMES
DW _{str,da,dt}			•	
Mapping	Dmnl	Mapping PRIMES-TIMES sectors	No	Defined
Sectors _{sp,st}	Dmal	Departmention of cooling in dwellings, have year value	No	Eviating data in IDC ELL TIMEC
	Dmnl	Penetration of cooling in dwellings, base year value	NO	Existing data in JRC-EU-TIMES
PRHEAT BY _{ct,da,dt}	Dmni	Penetration of neating in dwellings, base year value	INO Na	Existing data in JRC-EU-TIMES
Price elasticity _{st}	Dmni	Elasticity for the cost term	NO	Existing data in JRC-EU-TIMES
SAVEPER	Yea	The frequency with which output is stored (yearly).	No	Defined
SHAREDEMOLEX _{ct,dt}	Dmnl	Share of existing building categories in demolition	No	Existing data in JRC-EU-TIMES
SHARENEW _{ct,dt}	Dmnl	Share of building categories in new construction	Yes	Existing data in JRC-EU-TIMES
TARGCOOL _{ct}	Dmnl	Target penetration rate for cooling	Yes	Existing data in JRC-EU-TIMES
TARGHEAT _{ct}	Dmnl	Target penetration rate for heating	Yes	Existing data in JRC-EU-TIMES
TARGYEARCOOL _{ct}	Dmnl	Number of years for target penetration (cooling)	Yes	Existing data in JRC-EU-TIMES
TARGYEARHEAT _{ct}	Dmnl	Number of years for target penetration (heating)	Yes	Existing data in JRC-EU-TIMES
TEMPCOR _{ct}	Dmnl	Temperature correction for 2005 to multiply the heat demand	No	Existing data in JRC-EU-TIMES
		per dwelling		(Eurostat)
TOTDEMOL _{ct}	Dmnl	Share of dwellings demolished per year	Yes	Existing data in JRC-EU-TIMES
UNIT B	В	Billions (10e9)	No	Defined
UNIT POP	р	People	No	Defined
UNIT SAVINGS	X/d	Energy savings	No	Defined
UNIT TRANSPORT	Gxkm	Transport activity (Gpkm or Gtkm)	No	Defined

Name	Unit	Description	Policy parameter	Source
UNIT YEAR	Year	Time	No	Defined
UNIT €	€2010	€2010	No	Defined

3.2 Time series (input file "Data CY – Annual 20150921.xlsx")¹

Name	Unit	Description	Policy data	Source
DEMAND DAT _{ct,st}	X ²	Base year demand values	No	Existing data in JRC-EU- TIMES
DEMAND EU28 DAT _{st}	Х	Existing demand projection for EU28	No	Existing data in JRC-EU- TIMES
Driver elasticity _{st}	Dmnl	Elasticity for the driver term	No	Existing data in JRC-EU- TIMES
DWPERS _{ct}	p/d	Number of persons per dwellings	Yes	EU Reference Scenario (PRIMES)
ENERGY COST INDUSTRY _{ct}	€2010/toe	Unit cost of fuel purchasing as in PRIMES	Yes	EU Reference Scenario (PRIMES)
ENERGY COST RESIDENTIAL _{ct}	€2010/toe	Unit cost of fuel purchasing as in PRIMES	Yes	EU Reference Scenario (PRIMES)
ENERGY COST TERTIARY _{ct}	€2010/toe	Unit cost of fuel purchasing as in PRIMES	Yes	EU Reference Scenario (PRIMES)
ENERGY COST TRANSPORT _{ct}	€2010/toe	Unit cost of fuel purchasing as in PRIMES	Yes	EU Reference Scenario (PRIMES)
FINAL ENERGY DEMAND _{ct.sp}	РЈ	Final energy demand from PRIMES/EU Reference Scenario	Yes	EU Reference Scenario (PRIMES)
GDP _{ct}	B*€2010	GDP as in PRIMES/EU Reference Scenario	Yes	IRENA study

¹ Some time series are calculations from figures stored in "CY_GDP_forecast_IRENA_study.xlsx", "Energy balance 2013_v4.xlsx", and "JRC-IDEES_En_CY.xlsx".

² X=Gpkm for TCS, TCL, TBU, TMO, TTP, TTL. X=Gtkm for TFH, TFL, TTF. X=Mt for IIS, IAL, ICU, IAM, ICL, ICM, ILM, IGH, IGF, IPH, IPL. X=PJ for the rest.

Name	Unit	Description	Policy data	Source		
GDP SECTOR _{ct,sp}	B*€2010	Sectoral GDP as in PRIMES/EU Reference Scenario	Yes	IRENA study)		
HOUSEHOLD EXPENDITURE POP _{ct}	€2010/p	Household expenditures per capita	Yes	EU Reference Scenario (PRIMES)		
POP _{ct}	р	Population	Yes	IRENA study		
RATIO U2F DAT	Dmnl	Ratio useful-to-final energy from JRC-IDEES database	Yes (2011 onwards)	JRC-IDEES		
SPECIFIC ENERGY CONSUMPTION	PJ/X	Energy consumption per unit of physical output/activity	Yes (2011 onwards)	JRC-IDEES		
TRANSPORT ACTIVITY _{ct,spt}	Gxkm	Transport activity as in PRIMES/EU Reference Scenario	No	EU Reference Scenario (PRIMES)		

3.3 Variables

Name	Unit	Description	Source equation
COOLDW _{ct,da,dt}	X/d	Cooling demand per dwelling category from base year	19
COST TERM _{ct,st}	Dmnl	Energy cost driver	8
DEMAND _{ct,st}	Х	Projected demand,	1
DEMAND EQU _{ct,st}	Х	Projected demand	2
DEMAND EU28 _{st}	Х	Projected demand	Not included in the document
DEMAND F	PJ	Projected final demand	Not included in the document
DEMAND F REP	PJ	Projected final demand, aggregation for reporting	Not included in the document
DEMAND F REP CY	PJ	Projected final demand, aggregation for reporting	Not included in the document
DEMAND RATIO	Dmnl	Difference wrt projections for JET report 2013	Not included in the document
DEMAND U	PJ	Projected useful demand	Not included in the document
DEMAND U REP	PJ	Projected useful demand, aggregation for reporting	Not included in the document
DEMAND U REP CY	PJ	Projected useful demand, aggregation for reporting	Not included in the document
DEMDW _{ct,str}	X/d	Projected demand per dwelling	20
DEMOLEXI _{ct,dt}	d	Number of dwellings demolished per year by category	15
DEMSAVE _{ct,ime,strie}	Dmnl	Saving of demand in existing dwellings in percentage	Error! Reference source not found.

Name	Unit	Description	Source equation
DEMSAVN _{ct,imn,strin}	Dmnl	Saving of demand in new dwellings at construction in percentage	Error! Reference source not found.
DIFFERENCE DEMAND EU28 _{st}	Dmnl	Percentage difference between existing and projected demand	Not included in the document
DRIVER _{ct,st}	Dmnl	Drivers from PRIMES/EU Reference Scenario	7
DRIVER GR _{ct,st}	Dmnl	Driver growth rate as in PRIMES/EU Reference Scenario	6
DRIVER TERM _{ct,st}	Dmnl	Demand driver	5
DWSTOCK _{ct,da,dt}	d	Stock of dwelling by category and by construction period	13
DWSTOCKTOT _{ct}	d	Total stock of dwellings	12
EFFICIENCY TERM _{st}	Dmnl	Autonomous energy efficiency improvement term	11
ENERGY COST _{ct,sp}	€/toe	Unit cost of fuel purchasing as in PRIMES	10
ENERGY COST GR _{ct,sp}	Dmnl	Growth rate of unit cost of fuel purchasing as in PRIMES	9
FINAL ENERGY DEMAND EU28 _{sp}	PJ	Final energy demand from PRIMES/EU Reference Scenario	Not included in the document
GDP GR _{ct}	Dmnl	GDP growth rate as in PRIMES/EU Reference Scenario	Not included in the document
GDPPOP _{ct}	€2010/p	GDP per capita as in PRIMES/EU Reference Scenario	Not included in the document
GDPPOP GR _{ct}	Dmnl	GDP per capita growth rate as in PRIMES/EU Reference Scenario	Not included in the document
GRCOOLDW _{ct,strc}	Dmnl	Growth rate in cooling demand per heat demand category	23
GRHEATDW _{ct,strh}	Dmnl	Growth rate in heat demand per heat demand category	22
GRHOTWDW _{ct,strw}	Dmnl	Growth rate in hot water demand per hot water demand category	24
HEATDW _{ct,da,dt}	X/d	Heat demand per dwelling category from base year	17
HOTWDW _{ct}	X/d	Hot water demand per dwelling category from base year	18
PERSHEV _{ct}	Dmnl	Evolution in number of persons per dwelling	25
POP GR _{ct}	Dmnl	Population growth rate	Not included in the document
PRCOOL _{ct,da,dt}	Dmnl	Penetration of cooling in dwellings	26
SHAREEXIS _{ct.dt}	Dmnl	Share of existing dwellings on total, per dwelling type.	Not included in the document

4. Equations

4.1 Standard demand equations

The demand of energy services³ is projected according to the methodology described in $(1)^4$ and (2). Those projections are driven by a series of inputs exogenous to the model (available from the current JRC-EU-TIMES dataset and from the latest EU Reference Scenario (3)⁵). The main drivers of energy demand are projections on:

• Population, and

1

• GDP, sectoral production, and household consumption

The current implementation of the demand projections overwrites the result of the demand equation (DEMAND $EQU_{ct,st}$) whenever real data (DEMAND $DAT_{ct,st}$) are available:

 $DEMAND_{ct,st} =$ $IF THEN ELSE (DEMAND DAT_{ct,st} \neq NA^{6}, DEMAND DAT_{ct,st}, DEMAND EQU_{ct,st})$

The general equation for projecting the demand from the previous period (DEMAND $DLY_{ct,st}$) into the current one is the result of multiplying that demand by three factors, namely: i) a term related to the main driver behind the growth in the energy service demand (DRIVER TERM_{ct,st}), ii) a cost term that represents an estimation of the path of the corresponding energy prices (COST TERM_{ct,st}), and iii) a price- and driver-

In subsequent periods the demand would be: $E_{2} = E_{1} \cdot \left(\frac{D_{2}}{D_{1}}\right)^{IE} \cdot \left(\frac{P_{2}}{P_{1}}\right)^{PE} \cdot (1 - AEEI) \rightarrow E_{2} = E_{0} \cdot \left(\frac{D_{1}}{D_{0}}\right)^{2 \cdot IE} \cdot \left(\frac{P_{1}}{P_{0}}\right)^{2 \cdot PE} \cdot (1 - AEEI)^{2}$ \vdots $E_{T} = E_{T-1} \cdot \left(\frac{D_{T}}{D_{T-1}}\right)^{IE} \cdot \left(\frac{P_{T}}{P_{T-1}}\right)^{PE} \cdot (1 - AEEI) \rightarrow E_{T} = E_{0} \cdot \left(\frac{D_{1}}{D_{0}}\right)^{T \cdot IE} \cdot \left(\frac{P_{1}}{P_{0}}\right)^{T \cdot IE} \cdot (1 - AEEI)^{T}$ Rearranging: $E_{T} = E_{0} \cdot \left(\frac{D_{0} + D_{1} - D_{0}}{D_{0}}\right)^{T \cdot IE} \cdot \left(\frac{P_{0} + P_{1} - P_{0}}{P_{0}}\right)^{T \cdot PE} \cdot (1 - AEEI)^{T}$ $E_{T} = E_{0} \cdot (1 + DGR)^{T \cdot IE} \cdot (1 + PGR)^{T \cdot PE} \cdot (1 - AEEI)^{T}$ In the case of having different growth rates from 0 to T, the previous equation reads: $E_{T} = E_{0} \cdot \prod_{t=0}^{t=T} ((1 + DGR_{t})^{IE}) \cdot \prod_{t=0}^{t=T} ((1 + PGR_{t})^{PE}) \cdot \prod_{t=0}^{t=T} (1 - AEEI)^{5}$

³ Or materials, in the case of energy intensive sectors: IIS, IAL, ICU, IAM, ICL, ICM, ILM, IGH, IGF (expressed in Mt), and transport activities: TCS,TCL,TBU,TBI,TFH,TFL,TMO,TTP,TTF,TTL,TAV,TAI,TNA,TNB (expressed in pkm or tkm).

⁴ According to this methodology, the energy demand in period 1, E₁, is equal to the demand in period 0, E₀, multiplied by the growth in the driving demand (from D₀ to D₁, corrected by an income elasticity IE), the growth in energy costs (from P₀ to P₁, corrected by a price elasticity PE), and the autonomous energy efficiency improvement (AEEI): $E_1 = E_0 \cdot \left(\frac{D_1}{D_0}\right)^{L^E} \cdot \left(\frac{P_1}{P_0}\right)^{P_E} \cdot (1 - AEEI)$

⁵ <u>http://ec.europa.eu/energy/observatory/trends 2030/doc/trends to 2050 update 2013.pdf</u>

⁶ Keyword for "not available" in Vensim.

independent demand change due to autonomous efficiency improvements (EFFICIENCY TERM_{st}).

2 $DEMAND EQU_{ct,st} = DEMAND DLY_{ct,st} \cdot DRIVER TERM_{ct,st} \cdot COST TERM_{ct,st} \cdot EFFICIENCY TERM_{st} + CORRECTION_{ct,st}$ 3 $DEMAND DLY_{ct,st} = FIXED DELAY (DEMAND DLY_{ct,st}, SAVEPER⁷, DEMAND DAT_{ct,st}⁸)$

4.1.1 Driver term

The driver term in the demand equation is calculated as the growth rate between two consecutive periods corrected by the driver elasticity:

4 $DRIVER TERM_{ct,st} = \left(1 + \frac{DRIVER \ GR_{ct,st}}{100}\right)^{(SAVEPER \cdot Driver \ elasticity_{st})}$

The only exception is the driver for residential heat, which is corrected as well by the annual heat efficiency improvement on existing dwellings because of demolishing:

5 $DRIVER TERM_{ct,strh} = \left(1 - EFFEXI_{ct} + \frac{DRIVER \ GR_{ct,strh}}{100}\right)^{(SAVEPER \cdot Driver \ elasticity_{strh})}$

The growth rate of the driver (DRIVER $GR_{ct,st}$) is calculated as the compounded annual growth rate of the driver (DRIVER_{ct,st}) between two consecutive periods, that is:

$$DRIVER \ GR_{ct,st} = 100 \cdot \left(\left(\frac{DRIVER_{ct,st}}{DRIVER \ DLY_{ct,st}} \right)^{\left(\frac{1}{SAVEPER} \right)} - 1 \right)$$

The drivers are sector-dependent. In the case of agriculture, commercial, and industrial sectors the driver is the corresponding sectorial GDP. Residential demand is driven by household expenditure per capita.

⁷ Time step in the calculations, annual.

⁸ Value taken in the first calculation step.

$$DRIVER_{ct,sta} = \sum_{sp} (Mapping \ sectors_{sp,sta} \cdot GDP \ SECTOR_{ct,sp})$$

$$DRIVER_{ct,stc} = \sum_{sp} (Mapping \ sectors_{sp,stc} \cdot GDP \ SECTOR_{ct,sp})$$

$$DRIVER_{ct,sti} = (1 - EURS) \cdot \sum_{sp} (Mapping \ sectors_{sp,sti} \cdot GDP \ SECTOR_{ct,sp}) + EURS \cdot DEMAND \ EURS \ DAT_{ct,sti}$$

$$DRIVER_{ct,str} = HOUSEHOLD \ EXPENDITURE \ POP_{ct}$$

$$DRIVER_{ct,stt} = \sum_{sp} (Mapping \ sectors_{spt,stt} \cdot TRANSPORT \ ACTIVITY_{ct,spt})$$

4.1.2 Cost term

The cost term in the demand equation is calculated as the growth rate between two consecutive periods corrected by the price elasticity:

8
$$COST \, TERM_{ct,st} = \left(1 + \sum_{sp} \left(Mapping \, sectors_{sp,st} \cdot \frac{ENERGY \, COST \, GR_{ct,sp}}{100}\right)\right)^{(SAVEPER \cdot Price \, elasticity_{st})}$$

The growth rate of the energy costs (ENERGY COST $GR_{ct,st}$) is calculated as the compounded annual growth rate of the costs (ENERGY $COST_{ct,sp}$) between two consecutive periods, that is:

9
$$ENERGY \ COST \ GR_{ct,sp} = 100 \cdot \left(\left(\frac{ENERGY \ COST_{ct,sp}}{ENERGY \ COST \ DLY_{ct,sp}} \right)^{\left(\frac{1}{SAVEPER} \right)} - 1 \right)$$

The energy costs are sector-dependent, and taken from the latest EU Reference Scenario.

$$ENERGY COST_{ct,spi} = ENERGY COST INDUSTRY_{ct}$$

10

 $ENERGY COST_{ct,sp3} = ENERGY COST TERTIARY_{ct}$

 $ENERGY COST_{ct,spc} = ENERGY COST INDUSTRY_{ct}$

$$ENERGY COST_{ct,spt} = ENERGY COST TRANSPORT_{ct}$$

4.1.3 Efficiency term

The efficiency term in the demand equation is calculated as the compounded growth rate due to efficiency improvements ($AEEI_{st}$) between two consecutive periods:

```
11 \quad EFFICIENCY TERM_{st} = (1 - AEEI_{st})^{(SAVEPER)}
```

This term defines the price independent demand change due to autonomous efficiency improvements, and is an expert-based assumption. This is mainly used in the industrial sector to reflect intra-sectorial structural evolution not directly linked to changes in energy prices.

1.1.1 Elasticities

The evolution of the demand for energy services is linked to the changes in demand drivers' through elasticities. These elasticities are meant to reflect changing patterns in energy service demand in relation to economic growth, such as saturation in some energy end-use demand, increased urbanization or changes in consumption patterns once the basic needs are satisfied. Driver elasticities range from 0 to 1, and the lower the elasticity the less influence of the driver on the energy demand service. The values

- Passenger transport: there is shift from public transport towards private cars with increasing income; greater urbanisation would also contribute to a lesser increase in the passenger-km demand.
- Freight transport: accompanies more closely the growth of GDP with a slight model shift from road transport to other freight transport means.
- Residential demand: for space heating and cooling and for water heating the drivers are a combination of the evolution in the number of households, the population growth and disposable income per household. This combination is done after the GEM-E3 outcome. Within GEM-E3 the driver for the residential sector is only disposable income. For the other demand categories, the evolution in income is the dominant factor. In the long run, certain saturation and changes in consumption patterns will weaken this link.
- Commercial demand: follows the sectorial activity but with a decreasing link.
- Industrial and agriculture demand: the demand follows the sectorial production evolution.

Table 1: driver elasticities

Sector [code]	2005	2010	2015	2020	2025	2030	2035	2040	2045	2050
Iron and steel [IIS]	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.8
Aluminium [IAL]	1	1	1	1	1	1	1	1	1	1
Copper [ICU]	1	1	1	1	1	1	1	1	1	1
Other non- ferrous metals [INF]	1	1	1	1	1	1	1	1	1	1
Chemicals [ICH]	0.9	0.9	0.9	0.9	0.9	0.9	0.9	0.9	0.9	0.9
Ammonia [IAM]	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7
Chlorine [ICL]	0.9	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7
Cement [ICM]	0.9	0.9	0.9	0.9	0.9	0.9	0.9	0.9	0.9	0.9
Lime [ILM]	0.9	0.9	0.9	0.9	0.9	0.9	0.9	0.9	0.9	0.9
Glass, hollow [IGH]	1	1	1	1	1	1	1	1	1	1
Glass, flat [IGF]	1	1	1	1	1	1	1	1	1	1
Other non- metallic	1.1	1.1	1.1	1.1	1.1	1.1	1.1	1.1	1.1	1.1
Pulp and paper, high quality [IPH]	1	1	1	1	1	1	1	1	1	1
Pulp and paper, low quality [IPL]	1	1	1	1	1	1	1	1	1	1
Other industries [IOI]	1	1	1	1	1	1	1	1	1	1
Non energy consumption, chemicals [NEC]	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5
Non energy consumption, others [NEO]	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5
Residential heating in existing rural dwellings [RHRE]	0.5	0.5	0.3	0.2	0.2	0.2	0.2	0.2	0.2	0.2
Residential heating in existing urban dwellings [RHUE]	0.5	0.5	0.3	0.2	0.2	0.2	0.2	0.2	0.2	0.2
Residential heating in existing multi- apartment dwellings [RHME]	0.5	0.5	0.3	0.2	0.2	0.2	0.2	0.2	0.2	0.2
Residential cooling in existing rural dwellings [RCRE]	0.8	0.8	0.8	0.3	0.3	0.3	0.3	0.3	0.3	0.3
Residential cooling in	0.8	0.8	0.8	0.3	0.3	0.3	0.3	0.3	0.3	0.3

Sector [code]	2005	2010	2015	2020	2025	2030	2035	2040	2045	2050
existing urban dwellings [RCUE]										
Residential cooling in existing multi- apartment dwellings [RCME]	0.8	0.8	0.8	0.3	0.3	0.3	0.3	0.3	0.3	0.3
Residential hot water in existing rural dwellings [RWRE]	0.8	0.8	0.5	0.2	0.2	0.2	0.2	0.2	0.2	0.2
Residential hot water in existing urban dwellings [RWUE]	0.8	0.8	0.5	0.2	0.2	0.2	0.2	0.2	0.2	0.2
Residential hot water in existing multi-apartment dwellings [RWME]	0.8	0.8	0.5	0.2	0.2	0.2	0.2	0.2	0.2	0.2
Residential heating in new rural dwellings [RHRN]	0.5	0.5	0.3	0.2	0.2	0.2	0.2	0.2	0.2	0.2
Residential heating in new urban dwellings [RHUN]	0.5	0.5	0.3	0.2	0.2	0.2	0.2	0.2	0.2	0.2
Residential heating in new multi-apartment dwellings [RHMN]	0.5	0.5	0.3	0.2	0.2	0.2	0.2	0.2	0.2	0.2
Residential cooling in new rural dwellings [RCRN]	0.8	0.8	0.8	0.3	0.3	0.3	0.3	0.3	0.3	0.3
Residential cooling in new urban dwellings [RCUN]	0.8	0.8	0.8	0.3	0.3	0.3	0.3	0.3	0.3	0.3
Residential cooling in new multi-apartment dwellings [RCMN]	0.8	0.8	0.8	0.3	0.3	0.3	0.3	0.3	0.3	0.3
Residential hot water in new rural dwellings [RWRN]	0.8	0.8	0.5	0.2	0.2	0.2	0.2	0.2	0.2	0.2
Residential hot water in new urban dwellings [RWUN]	0.8	0.8	0.5	0.2	0.2	0.2	0.2	0.2	0.2	0.2
Residential hot water in new multi-apartment dwellings	0.8	0.8	0.5	0.2	0.2	0.2	0.2	0.2	0.2	0.2

Sector [code]	2005	2010	2015	2020	2025	2030	2035	2040	2045	2050
[RWMN]										
Residential lighting existing [RLIG]	1.5	1.5	0.5	0.25	0.25	0.25	0.25	0.25	0.25	0.25
Residential cooking existing [RCOK]	0.3	0.3	0.2	0.15	0.15	0.15	0.1	0.1	0.1	0.1
Residential refrigeration existing [RREF]	0.3	0.3	0.2	0.15	0.15	0.15	0.1	0.1	0.1	0.1
Residential cloth washing existing [RCWA]	0.3	0.3	0.2	0.15	0.15	0.15	0.1	0.1	0.1	0.1
Residential cloth drying existing [RCDR]	0.5	0.5	0.2	0.25	0.25	0.25	0.1	0.1	0.1	0.1
Residential dish washing existing [RDWA]	0.5	0.5	0.2	0.25	0.25	0.25	0.1	0.1	0.1	0.1
Residential other electric existing [ROEL]	2	2	0.8	0.5	0.5	0.5	0.25	0.25	0.25	0.25
energy existing [ROEN]	0.3	0.3	0.3	0.25	0.25	0.25	0.25	0.25	0.25	0.25
Commercial small space heating existing [CHSE]	0.6	0.6	0.35	0.2	0.2	0.2	0.2	0.2	0.2	0.2
Commercial large space heating existing [CHLE]	0.6	0.6	0.35	0.2	0.2	0.2	0.2	0.2	0.2	0.2
Commercial small space cooling existing [CCSE]	0.5	0.5	0.5	0.4	0.4	0.4	0.4	0.4	0.4	0.4
Commercial large space cooling existing [CCLE]	0.5	0.5	0.5	0.4	0.4	0.4	0.4	0.4	0.4	0.4
Commercial small space hot water existing [CWSE]	0.6	0.6	0.4	0.3	0.3	0.3	0.3	0.3	0.3	0.3
Commercial large space hot water existing [CWLE]	0.6	0.6	0.4	0.3	0.3	0.3	0.3	0.3	0.3	0.3
Commercial lighting existing [CLIG]	1.5	1.5	0.4	0.3	0.3	0.3	0.3	0.3	0.3	0.3
Commercial cooking existing [CCOK]	0.8	0.8	0.3	0.3	0.3	0.3	0.3	0.3	0.3	0.3
Commercial refrigeration existing [CREF]	0.8	0.8	0.4	0.3	0.3	0.3	0.3	0.3	0.3	0.3
Commercial	0.8	0.8	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2

Sector [code]	2005	2010	2015	2020	2025	2030	2035	2040	2045	2050
public lighting existing [CPLI]										
Commercial other electric existing [COEL]	2	2	1.5	1	1	1	0.6	0.6	0.6	0.6
Commercial other energy existing [COEN]	0.8	0.8	0.4	0.4	0.4	0.4	0.4	0.4	0.4	0.4
Other non- energy [ONE]	0	0	0	0	0	0	0	0	0	0
Agriculture [AGR]	0.6	0.6	0.5	0.3	0.3	0.3	0.3	0.3	0.3	0.3
Road car short distance [TCS]	1	1	1	1	1	1	1	1	1	1
Road car long distance [TCL]	0.9	0.9	0.8	0.7	0.7	0.7	0.6	0.6	0.6	0.6
Road bus urban [TBU]	1	1	1	1	1	1	1	1	1	1
Road bus intercity [TBI]	1	1	1	1	1	1	1	1	1	1
Road freight heavy [TFH]	1	1	1	0.8	0.8	0.8	0.8	0.8	0.8	0.8
Road freight light [TFL]	1	1	1	0.8	0.8	0.8	0.8	0.8	0.8	0.8
Road motorcycles [TMO]	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5
Rail passengers heavy [TTP]	1	1	1	1	1	1	1	1	1	1
Rail freight [TTF]	0.9	0.9	0.9	0.9	0.9	0.9	0.9	0.9	0.9	0.9
Rail passengers light [TTL]	1	1	1	1	1	1	1	1	1	1
Aviation generic [TAV]	1.2	1.2	1.2	1	1	1	1	1	1	1
Aviation international [TAI]	1.2	1.2	1.2	1	1	1	1	1	1	1
Navigation generic [TNA]	0.9	0.9	0.9	0.9	0.9	0.9	0.9	0.9	0.9	0.9
Navigation generic bunker [TNB]	0.9	0.9	0.9	0.9	0.9	0.9	0.9	0.9	0.9	0.9

Besides the driver elasticities, the demand projections depend as well on price elasticities. There are no studies on price elasticities of energy service demand, except for transport. Therefore the price elasticities are derived from energy demand price elasticities.

At an aggregate level, energy demand (ED) is equal to the energy service demand (ES) multiplied by the energy efficiency of the process used to satisfy the energy demand (UE, the energy demand per unit of energy service demand, a function of capital and energy). Depending on the substitution possibilities between inputs and processes, the relation between the two elasticities will be different.

 $\mathsf{A} \quad ED = ES \cdot UE$

Assuming a fixed relation between capital and energy in the production function of energy services (Leontief structure), the price elasticity of energy demand (PED) is equal to the product of the price elasticity of energy service demand (PES) and the share of energy in the total cost of the energy service (SHC):

$$\mathsf{B} \quad PED = PES \cdot SHC$$

Assuming substitution possibilities between capital and energy in the production function (a production function with constant elasticity of substitution), the price elasticity of energy demand will also depend on the substitution elasticity (SEL):

$$C \quad PED = PES \cdot SHC - SEL \cdot (1 - SHC)$$

Thus, the greater the share of energy in the total cost of the energy service, the closer both elasticities are, while they differ more the greater the substitution possibilities are.

Based on the relations and assumptions regarding the energy demand price elasticities and substitution possibilities the following energy services demand price elasticities are used in the JRC-EU-TIMES model. For transport there are estimates of the price elasticities of demand, although they do not cover all the regions and are sometimes related to the cost of energy and not the total transport cost. The values considered in JRC-EU-TIMES are from average figures for long term elasticities in OECD countries.

Table 2: price elasticities

Demand	Price elasticity of energy demand (PED)	Substitution elasticity (SEL)	Share of energy in energy service costs (SHC)	Price elasticity of energy service demand (PES)
Residential heating, cooling, and hot water	-0.45	0.70	0.80	-0.39
Residential cooking and refrigeration	-0.35	0.40	0.80	-0.34
Commercial heating, cooling and hot water	-0.55	0.70	0.80	-0.51
Commercial cooking and refrigeration	-0.40	0.40	0.80	-0.40
Energy intensive industries	-0.70	1.00	0.70	-0.57

20

Demand	Price elasticity of energy demand (PED)	Substitution elasticity (SEL)	Share of energy in energy service costs (SHC)	Price elasticity of energy service demand (PES)
Other industries	-0.40	0.40	0.80	-0.40
Private car				-0.70
Bus				-0.20
Train				-0.20
Motorcycles				-0.30
Navigation				-0.10
Air				-0.70
Trucks				-0.90
Train				-0.20
Navigation				-0.20

4.2 Energy demand in the residential sector

The approach used to project the demand from the residential sector is more specific, as described in the following. The energy service demands considered in the residential sector are listed below:

- Space heating,
- Space cooling,
- Water heating,
- Cooking,
- Refrigeration,
- Lighting,
- Cloth washing,
- Cloth drying,
- Dish washing,
- Other electric uses (equipment) and
- Other energy uses.

The demand for heating, cooling, and hot water is related to the characteristics of the dwellings and thus, in order to achieve a more detailed description, those demands are further disaggregated into three categories of buildings:

- Multi-family apartment buildings,
- Single houses in urban areas, and
- Single houses in rural areas.

Therefore the projection for the energy service demands from the residential sector is done in three steps:

- Projection of the number of dwellings, by category (section 0),
- Projection of the demand for heating, cooling, and hot water, per dwelling and by category (section 0),
- Projection of the total demand by combining the previous (section 0).

4.2.1 Stock of dwellings by category

The projected number of total households (DWSTOCKTOT_{ct}) is derived from the population level (POP_{ct}) and the number of persons per household (DWPERS_{ct}) assumed in the latest EU Reference Scenario, except in the initial year, when the stock of existing dwellings is taken from the calibrated template files (based on Eurostat data, where available, and on national experts input when not available):

$$DWSTOCKTOT_{ct} = INITIAL TIME, \sum_{dt} DWSTOCKBASE_{ct,dt}, \frac{POP_{ct}}{DWPERS_{ct}}$$

The number of existing dwellings remaining in each period (DWSTOCK_{ct,EXISTING,dt}) is computed as the difference between the previous stock (DWSTOCK DLY_{ct,EXISTING,dt}), the number of existing buildings demolished (DEMOLEXI_{ct,dt}), and the new dwellings (DWSTOCK_{ct,NEW,dt}):

	$DWSTOCK_{ct,dt} =$
	IF THEN ELSE (Time
13	$= INITIAL TIME, DWSTOCKSHARE_{ct,dt}$
	$\cdot DWSTOCKTOT DAT_{ct}, max(0, DWSTOCK DLY_{ct, EXISTING, dt} - DEMOLEXI_{ct, dt}$
	$+ DWSTOCK_{ct,NEW,dt}))$
	DWSTOCK DLY _{ct,dt}
14	= $DELAY FIXED(DWSTOCK DLY_{ct,dt}, SAVEPER, DWSTOCKSHARE IV_{ct,dt})$
	$\cdot DWSTOCKTOT IV_{ct}$)

The number of existing buildings demolished per category is calculated from the total share of demolitions⁹ (TOTDEMOL_{ct}, exogenous) and the share of each dwelling category in demolition (SHAREDEMOLEX_{ct}, dt, exogenous):

¹⁵
$$DEMOLEXI_{ct,dt} = DWSTOCKTOT_{ct} \cdot TOTDEMOL_{ct} \cdot SHAREDEMOLEX_{ct,dt}$$

It is assumed that demolishing mainly affects the oldest dwellings with the highest unit heat demand thus inducing an 'efficiency' improvement for the average stock. In JRC-EU-TIMES a mixed approach was used to compute an efficiency improvement factor for existing stock. For countries for which detailed survey data on the housing stock

⁹ With respect to the occupied dwellings.

structure and the demolishing rate is available, a specific factor was used. For other countries, the efficiency factor was estimated based on the assumption that there is no distinction for type of dwelling.

The number of new dwellings (DWSTOCK_{ct,NEW,dt}) by category is estimated by multiplying the share of each building category in new constructions (SHARENEW_{ct,dt}) by the difference between the projected total number of households (DWSTOCKTOT_{ct}), the total stock of existing dwellings remaining, and the demolished dwellings (DEMOLEXI_{ct,dt}) in each period:

 $DWSTOCK_{ct,NEW,dt}$ $= SHARENEW_{ct,dt} \cdot MAX\left(0, DWSTOCKTOT_{ct} - \sum_{dt} DWSTOCK_{ct,EXISTING,dt}\right)$ $+ DEMOLEXI_{ct,dt}$

The allocation of the total stock by building type is done with exogenous shares based on assumptions such as urbanisation trends and age pattern evolution. These assumptions were made by the several national experts involved in the NEEDS11 and RES202012 research projects.

4.2.2 Demand of energy services per dwelling

The starting point to generate the demand of energy services per dwelling is to calculate them according to the calibrated values for the base year in the residential template for each region in the model (HEATDW_{ct,da,dt}, COOLDW_{ct,da,dt}, HOTWDW_{ct,da,dt}). In the case of the demand for heating in existing buildings, the estimation is corrected (by the TEMPCOR_{ct} factor) since for some countries 2010 was not an average year regarding heating and cooling degree days (in the current implementation the computation does not consider the possible impacts of future climate change on heating and cooling). The demand of heating from new dwellings is based on the demand from existing dwellings corrected by exogenous factors (DIFHEAT_{ct,d}):



Once the base year demands per dwelling are calculated the projections (DEMDW_{ct,str}) are derived as follows. For existing dwellings the energy demands are the result of multiplying the average demand of existing and new dwellings added in the previous period by the growth rate in energy demand. In the case of new dwellings, the current energy demand is calculated as the product of the demand in the previous period by the growth rate.





The growth rates of the demand of energy services per dwelling are calculated as the product of the driver, costs, and efficiency terms (and also by the change in the number of persons per dwelling in the case of the demand of how water):

22
$$GRHEATDW_{ct,strh} = DRIVER TERM_{ct,strh} \cdot COST TERM_{ct,strh} \cdot EFFICIENCY TERM_{strh}$$
23
$$GRCOOLDW_{ct,strc} = DRIVER TERM_{ct,strc} \cdot COST TERM_{ct,strc} \cdot EFFICIENCY TERM_{strc}$$
24
$$GRHOTWDW_{ct,strw} = DRIVER TERM_{ct,strw} \cdot EFFICIENCY TERM_{strw} \cdot \left(1 + \frac{PERSHEV_{ct}}{100}\right)^{SAVEPER}$$

The change in the number of persons per dwelling ($PERSHEV_{ct}$) is calculated as:

25
$$PERSHEV_{ct} = 100 \cdot \left(\left(\frac{DWPERS_{ct}}{DWPERS DLY_{ct}} \right)^{\frac{1}{SAVEPER}} - 1 \right)$$

4.2.3 Total demand of energy services

The demand of residential heat, cooling and hot water is calculated by multiplying the demand per dwelling (DEMDW_{ct,str}) by the corresponding stock of dwellings (DWSTOCK_{ct,da,dt}). In all cases the residential demand is mapped to the different dwelling types and ages by a constant (Mapping RD AGE DW_{str,da,dt}) taking 1-0 values (mapped-not mapped).

2

$$DEMAND EQU_{ct,strh} = \frac{DEMDW_{ct,strh}}{TEMPCOR_{ct}} \cdot \sum_{da,dt} (DWSTOCK_{ct,da,dt} \cdot PRHEAT_{ct}Mapping RD AGE DW_{strh,da,dt})$$

$$DEMAND EQU_{ct,strw} = DEMDW_{ct,strw} \cdot \sum_{da,dt} (DWSTOCK_{ct,da,dt} \cdot Mapping RD AGE DW_{strw,da,dt})$$

$$DEMAND EQU_{ct,strc} = DEMDW_{ct,strc} \cdot \sum_{da,dt} (DWSTOCK_{ct,da,dt} \cdot PRCOOL_{ct,da,dt} \cdot Mapping RD AGE DW_{strw,da,dt})$$

In the case of the demand of residential heat, the demand for the first year is corrected by a factor (TEMPCOR_{ct}) that accounts for observed deviations from average temperatures and the penetration of heating in dwellings (PRHEAT_{ct}). The demand for residential cooling takes into account the penetration of cooling in dwellings (PRCOOL_{ct,da,dt}), which depends on its previous value and the difference between the cooling penetration target and the initial value in the base year:

26

$$PRCOOL_{ct,da,dt} = \frac{PRCOOL_{ct,da,dt} + \frac{(TARGCOOL_{ct} - PRCOOL BY_{ct,da,dt})}{TARGYEARCOOL_{ct}}}{PRHEAT_{ct,da,dt}} = \frac{PRHEAT_{ct,da,dt}}{PRHEAT DLY_{ct,da,dt}} + \frac{(TARGHEAT_{ct} - PRHEAT BY_{ct})}{TARGYEARHEAT_{ct}}}{PRHEAT_{ct}}$$

5 Results

5.1 Economic and demographic assumptions

Gross domestic product is expected to grow from 17.33 B \in 2010 in 2010 to 31.02 B \in 2010 by 2050, according the economic projections assumed by IRENA's "Renewable Energy Roadmap for the Republic of Cyprus"¹⁰.



Figure 1: GDP projections

As regards population, it is expected to increase from 839800 inhabitants in 2010 to 888670 by 2050.



Figure 2: population projection

¹⁰ <u>http://www.irena.org/DocumentDownloads/Publications/IRENA Cyprus Roadmap Report 2015.pdf</u>

5.2 Industrial useful energy demand

The main energy consuming industry is the cement sector, which is assumed to increase its production from 0.86 Mt in 2013 to 1.18 Mt in 2050. This would translate into an useful energy consumption change from 2.85 PJ in 2013 to 3.92 PJ by 2050, assuming an energy intensity of 0.84 PJ/Mt throughout the projection period.



Figure 3: projected cement production

Other sectors with significant energy consumption would be the chemical industry, the non-metallic minerals sector (manufacturing of bricks), and other industries (small workshops). The later would increase 2.43 PJ in 2013 to 4.15 PJ by 2050. Energy consumption from the non-metallic minerals sector would change from 0.49 PJ to 0.67 PJ in the same period, while the chemical sector would increase from 0.19 PJ to 0.33 PJ.



Figure 4: energy demand projections

Heating and other applications would be main industrial energy uses throughout the whole projection period, changing respectively from 5.15 PJ in 2013 to 6.89 PJ in PJ, and from 2.04 PJ to 3.89 PJ.



5.3 Residential energy demand

Residential energy demand is driven by the evolution of the dwelling stock and the expected occupancy rate per dwelling. This rate would decrease from 2.88 persons per dwelling in 2013 to 2.69 by 2050.



Figure 5: expected occupancy per dwelling

As regards the dwelling stock by the end of the year, it would increase from 302692 dwellings in 2013 to 330522 in 2050.



Figure 6: number of dwellings at the end of the year

Assuming a yearly demolition rate of 0.00025 % of stock at the end of the previous year, the amount of demolished dwellings would increase from 75 to 85.



Figure 7: dwellings demolished during the year

New additions to the dwelling stock would therefore increase from 1995 in 2013 to 85 by 2050.



Figure 8: new dwellings

Total energy for residential uses would increase from 15.99 PJ in 2013 to 24.27 PJ in 2050. Demand from new dwellings would be negligible, according the assumptions used. Most of the energy would be used for cooling, varying from 6.06 PJ in 2013 to 12.85 PJ in 2050.



Figure 9: residential cooling demand

The second most important use would be heating, which would increase from 5.19 PJ in 2013 to 5.96 PJ in 2050.



Figure 10: residential heating demand

Energy demand for hot water would increase from 1.88 PJ in 2013 to 2.23 PJ in 2050.



Figure 11: residential hot water demand

Energy demand for lighting and appliances would increase from 2.84 PJ in 2013 to 3.21 PJ in 2050.



Figure 12: residential demand from lighting and use of appliances

During the simulation period all residential energy uses are expected to increase very moderately, except cooling which would roughly double from 6.06 PJ in 2013 to 12.86 PJ in 2050.



5.4 Commercial energy demand

In the commercial sector, energy use would grow from 12.16 PJ in 2013 to 15.35 PJ in 2050. Most of that energy would be consumed for cooling, changing from 5.85 PJ in 2013 7.49 PJ in 2050.



Figure 13: commercial demand for cooling

Lighting and other services would the second most important use, increasing from 3.35 PJ in 2013 4.49 PJ in 2050.



Figure 14: commercial demand for lighting and other services

Commercial heating would change from 2.24 PJ in 2013 to 2.51 PJ in 2050.



Figure 15: commercial demand for heating

Commercial hot water demand would slightly increase, from 0.72 PJ in 2013 0.86 PJ in 2050.



Figure 16: commercial hot water demand

As in the case of the residential sector, cooling would be the energy use experiencing the most significant growth during the simulation period, increasing from 5.85 PJ in 2013 to 7.49 PJ in 2050.



5.4 Agriculture

Energy use in the agricultural sector would remain virtually constant around 1.44 PJ throughout the whole simulated period.



Figure 17: demand from agriculture

6 References

1. Kanudia, Amit and Regemorter, Denise van. *Projections of the demand of energy services for NEEDS EU Research Project.* s.l. : Unpublished, 2006.

2. **Simoes, Sofia, et al., et al.** *The JRC-EU-TIMES model - Assesing the long-term role of the SET Plan energy technologies.* European Commission, Joint Research Cente, Institute for Energy and Transport. Luxembourg : Publications Office of the European Union, 2013. Scientific and Technical Research series. EUR 26292.

3. European Commission. *EU energy, transport, and GHG emissions trends to 2050 - Reference scenario 2013.* s.l. : European Commission, 2013.

List of figures

Figure 1: GDP projections	28
Figure 2: population projection	28
Figure 3: projected cement production	29
Figure 4: energy demand projections	29
Figure 5: expected occupancy per dwelling	30
Figure 6: number of dwellings at the end of the year	31
Figure 7: dwellings demolished during the year	31
Figure 8: new dwellings	32
Figure 9: residential cooling demand	32
Figure 10: residential heating demand	33
Figure 11: residential hot water demand	33
Figure 12: residential demand from lighting and use of appliances	34
Figure 13: commercial demand for cooling	35
Figure 14: commercial demand for lighting and other services	35
Figure 15: commercial demand for heating	36
Figure 16: commercial hot water demand	36
Figure 17: demand from agriculture	37

List of tables

Table 1: driver elasticities	16
Table 2: price elasticities	20

Europe Direct is a service to help you find answers to your questions about the European Union Free phone number (*): 00 800 6 7 8 9 10 11

(*) Certain mobile telephone operators do not allow access to 00 800 numbers or these calls may be billed.

A great deal of additional information on the European Union is available on the Internet. It can be accessed through the Europa server http://europa.eu

How to obtain EU publications

Our publications are available from EU Bookshop (<u>http://bookshop.europa.eu</u>), where you can place an order with the sales agent of your choice.

The Publications Office has a worldwide network of sales agents. You can obtain their contact details by sending a fax to (352) 29 29-42758.

JRC Mission

As the Commission's in-house science service, the Joint Research Centre's mission is to provide EU policies with independent, evidence-based scientific and technical support throughout the whole policy cycle.

Working in close cooperation with policy Directorates-General, the JRC addresses key societal challenges while stimulating innovation through developing new methods, tools and standards, and sharing its know-how with the Member States, the scientific community and international partners.

Serving society Stimulating innovation Supporting legislation

