



EUROPEAN
COMMISSION

Brussels, **XXX**
[...](2016) **XXX** draft

ANNEX 1

ANNEX

to the

Commission Regulation (EU)../..

establishing a network code on electricity emergency and restoration

ANNEX

to the

Commission Regulation (EU)..../..

establishing a network code on electricity emergency and restoration

ANNEX

Automatic low frequency demand disconnection scheme characteristics:

| Parameter | Values SA Continental Europe | Values SA Nordic | Values SA Great Britain | Values SA Ireland | Measuring Unit |
|---|------------------------------|------------------|-------------------------|-------------------|--|
| Demand disconnection starting mandatory level : Frequency | 49 | 48.7 – 48.8 | 48.8 | 48.85 | Hz |
| Demand disconnection starting mandatory level: Demand to be disconnected | 5 | 5 | 5 | 6 | % of the Total Load at national level |
| Demand disconnection final mandatory level: Frequency | 48 | 48 | 48 | 48.5 | Hz |
| Demand disconnection final mandatory level: Cumulative Demand to be disconnected | 45 | 30 | 50 | 60 | % of the Total Load at national level |
| Implementation range | ±7 | ±10 | ±10 | ±7 | % of the Total Load at national level, for a given Frequency |
| Minimum number of steps to reach the final mandatory level | 6 | 2 | 4 | 6 | Number of steps |
| Maximum Demand disconnection for each step | 10 | 15 | 10 | 12 | % of the Total Load at national level, for a given step |